



**BRANDON**  
SCHOOL DIVISION  
WWW.BSD.CA

# WATER SAMPLING TEST RESULTS 2020-2021

**TYPES OF FIXTURES TESTED:**

- \* BOTTLE-FILLER STATIONS
- \* WATER MAIN VALVE
- \* FAUCETS (KITCHEN, STAFF ROOM HOME ECONOMICS ETC.)

**ALLOWABLE LIMITS:**

LEAD: 0.005 MG/L

SCHOOL	ADDRESS	# LOCATIONS TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	SHORT / LONG TERM CORRECTIVE MEASURES
Alexander School	PO Box 21 Alexander, MB R0K 0A0	3	Nil	NA	NA
Betty Gibson School	701 - 12th Street Brandon, MB R7A 6H7	6	Nil	NA	NA
Crocus Plains Regional Secondary School	1930 - 1st Street Brandon, MB R7A 6Y6	25	1	Closed off – Do not drink	Flushing fixture
Administration Office	1031 - 6th Street Brandon, MB R7A 4K5	3	Nil	NA	NA
Earl Oxford School	540 - 18th Street Brandon, MB R7A 5B2	9	NIL	NA	NA
George Fitton School	1129 - 3rd Street Brandon, MB R7A 3E7	6	Nil	NA	NA
Green Acres School	335 Queens Avenue E. Brandon, MB R7A 2B9	3	Nil	NA	NA
École Harrison	415 Queens Avenue Brandon, MB R7A 1K9	7	Nil	NA	NA



**BRANDON**  
SCHOOL DIVISION  
WWW.BSD.CA

# WATER SAMPLING TEST RESULTS 2020-2021

SCHOOL	ADDRESS	# LOCATIONS TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	SHORT / LONG TERM CORRECTIVE MEASURES
J.R. Reid School	813 - 26th Street Brandon, MB R7B 2B6	6	Nil	NA	NA
King George School	535 Park Street Brandon, MB R7A 6M6	6	Nil	NA	NA
Kirkcaldy Height School	10 Knowlton Drive Brandon, MB R7A 6N7	6	Nil	NA	NA
Linden Lanes School	49 Silver Birch Drive Brandon, MB R7B 1A8	4	Nil	NA	NA
Facilities & Transportation Office	800 Richmond Avenue E. Brandon, MB R7A 7T8	2	Nil	NA	NA
Meadows School	1220 - 22nd Street Brandon, MB R7B 1T4	10	Nil	NA	NA
École secondaire Neelin High School	1020 Brandon Avenue Brandon, MB R7A 1K6	9	Nil	NA	NA
École New Era School	527 Louise Avenue Brandon, MB R7A 0X1	7	Nil	NA	NA
École O'Kelly School	PO Box 70 CFB Shilo, MB R0K 2A0	5	Nil	NA	NA
Riverheights School	32 E. Fotheringham Dr. Brandon, MB R7B 3G3	18	Nil	NA	NA



**BRANDON**  
SCHOOL DIVISION  
WWW.BSD.CA

# WATER SAMPLING TEST RESULTS 2020-2021

SCHOOL	ADDRESS	# LOCATIONS TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	SHORT / LONG TERM CORRECTIVE MEASURES
Riverview School	1105 Louise Avenue E. Brandon, MB R7A 1Y2	3	Nil	NA	NA
St. Augustine School	330 - 3rd Street Brandon MB R7A 3C3	3	Nil	NA	NA
Valleyview Centennial School	65 Whillier Drive Brandon, MB R7B 0X8	5	Nil	NA	Nil
Vincent Massey High School	715 McDiarmid Drive Brandon, MB R7B 2H7	17	Nil	NA	NA
Waverly Park School	3800 Park Avenue Brandon, MB R7B 3X2	5	Nil	NA	NA